

No : C.17-0900-R01  
Participant : Tekpan Teknik Elk. Kumanda Pano San. Ve Turizm Tic. A.Ş.  
Manufacturer : Tekpan Teknik Elk. Kumanda Pano San. Ve Turizm Tic. A.Ş.  
Product Description : Teos Series Form 4B Panel  
Model : Teos Series Form 4B Panel  
Technical Data : 2215 x 2110 x 610 mm  
60 kA/300 ms - IP55 – 400 V  
Test Standard : IEC 61641:2014  
Subject : Testing – Arc Fault Tests  
Applied Tests : Arc Fault Test  
Test Report Number : 17-0900-R01  
Certificate Date : 03.08.2017

Person in Charge of Test

Ata Gürül ARSLANLI

Head of Testing Laboratory

Cahit GÖKSEL



FRL.64

[www.lvt.com.tr](http://www.lvt.com.tr)

